RELAYbility





INSTANTANEOUS RELAYS. WELD-NO-TRANSFER 8 CONTACTS

FORCIBLY GUIDED CONTACTS

APPLICATIONS















Shipbuilding

Power generation

distribution

OVERVIEW

- Forcibly guided (mechanically linked) contacts, relays compliant with EN 61810-3, type A, certified by TUV Rheinland
- Weld-no-transfer technology
- Plug-in monostable instantaneous relays
- · Suitable for safety applications
- Solid and rugged construction for intensive duty
- Self-cleaning knurled contacts
- Very high electrical life expectancy and exceptional endurance
- Magnetic arc blow-out for higher breaking capacity
- Wide option range: signalling LED, FLYBACK DIODE, varistor, etc.
- Cover with matte finishing with access for manual operation (standard) and pull-out handle

DESCRIPTION

RMGX relays are highly reliable products featuring high performance, suitable for applications in very harsh and disturbed environments, such as **ROLLING STOCK** applications.

Referring to the standard EN61810-3, these relays are classified as fully compliant and identified as type A relays, (all the contacts are mechanically linked). By way of further quality and safety certification for users, relays are certified by TÜV Rheinland laboratories.

Equipped by C/O contacts: the user have the greatest possible flexibility in designing (6 NC + 2 NO, 5 NC + 3 NO, etc.).

Wide contact gap for a very high breaking capacity, electrical life expectancy and insulation.

The operating temperature range is -40°C to +85°C (as option). RMG can operate in environment with high thermal shocks.

Manual operation as standard for all models, allowing tests to be conducted in the absence of any power supply.

The contacts are designed to obtain remarkable performances both for high, inductive loads or very low loads. Each contact is able to switch from 10mA - 10V at new relay.

The knurled surface ensures an excellent self-cleaning effect, a lower ohmic resistance thanks to the various points of electrical contact, and will also improve the electrical life of the component.

The magnetic arc blow-out contributes to increase breaking capacity: the relay is suitable for controlling heavy duty loads with intensive switching frequency.

In this relay range with forcibly guided contacts (mechanically linked) special design and constructional measures are used to ensure that make (NO) contacts cannot assume the same state as break (NC) contacts.

- If, when powering up a relay, a NC contact fails to open, the remaining NO contacts must not close, maintaining a contact gap ≥0.5 mm
- When the relay is de-energized, if a NO contact fails to open, the remaining NC contact must not close, maintaining a contact gap ≥0.5 mm

In the case of relays that include changeover contacts, either the make circuit or the break circuit of a changeover contact can be considered to meet the requirements of this standard.

STANDARD COMPLIANCE

EN 61810-3 ASTM E162, E662 EN 60077 EN 61810-1 EN 61810-7 EN 50155 EN 60695-2-10 EN 61373 EN 60529 EN 45545-2





FOR PRODUCT CODE CONFIGURATION, SEE THE "ORDERING SCHEME" TABLE

COIL DATA		RMGExyX - RMGFxyX	RMGRxyX	
Nominal voltages Un		DC: 24-48-110-125-132-220 ⁽¹⁾	DC : 24-36-72-96-110 ⁽²⁾	
Consumption at Un (DC/AC)		3W		
	Operating range	DC : 80÷115% Un	DC : 70÷125% Un	
	Type of duty	Continuous		
	Drop-out voltage ⁽³⁾	DC : > 5% Un		


⁽¹⁾ Other values on request.

⁽³⁾ Limit value for supply voltage, expressed as % of the nominal value, beneath which the relay is certain to be de-energized.

ONTACT DATA		RMG.12X-16X-42X-46X	RMG.32X-36X-52X-56X-62X-66X	
Number and type		6 SPDT+ 2 NO, form C		
Current Nominal		See fol	llowing graph	
	Maximum peak (1)	20A for 1	min - 40A for 1s	
	Maximum pulse (1)	150,	A for 10ms	
Example of electrical life expectancy Minimum load (2) Standard contacts Gold-plated contacts (3)		RMG.x2X : 0.5A - 110Vdc - L/R 40ms - 10^5 operations - 1,800 operations / hour RMG.x6X : 1A - 110Vdc - L/R 40ms - 10^5 operations - 1,800 operations / hour		
		200-21/1/40/1/40-20/		
		200mW (10V, 10mA) 50mW (5V, 5mA)		
Max	kimum breaking voltage	350 VDC / 440 VAC		
	Contact material	ļ	AgCdO	
Оре	erating time at Un (ms) (4)	DC		
Pick-ı	ıp (NC contact opening)	≤ 35		
Pick-	up (NO contact closing)		≤ 60	
Drop-o	ut (NO contact opening)	≤ 4		
Drop-c	out (NC contact closing):	≤ 45		

⁽f) Maximum peak and pulse currents are those currents that can be handled, for a specified time, by the contact. They do not refer to steady or interrupted currents.

RATED CURRENT CONTACTS



Environmental Temperature

Note: reduction of 30% on all the contacts simultaneously.



⁽²⁾ Suitable for application on rolling stock. Operating range in compliance with EN 60077 standard.

⁽²⁾ Values referred to a new product, measured in laboratory. The ability to maintain this performance over the time depends on the environmental conditions and the contact' frequency use. The use of gold plated contacts is recommended in the case of very low loads. For a correct contact use, refer to the chapter "Installation, operation and maintenance".

⁽³⁾ A gold contact, if subjected to high loads, degrades superficially. In this case, the characteristics of the standard contact must be considered. This does not affect the operation of the relay.

⁽⁴⁾ Unless specified otherwise, the operating time signifies until stabilization of the contact (including bounces).

Insulation resistance (at 500VCD)	
,	
between electrically independent circuits and between these circuits and ground	> 10,000 MΩ
between open contact parts	> 10,000 MΩ
Withstand voltage at industrial frequency	
between electrically independent circuits and between these circuits and ground	2 kV (1 min.) - 2.2kV (1 s)
between open contact parts	2 kV (1 min.) - 2.2kV (1 s)
between adjacent contacts	2 kV (1 min.) - 2.2kV (1 s)
Impulse withstand voltage (1,2/50μs - 0,5J)	
between electrically independent circuits and between these circuits and ground	5 kV
between open contact parts	5 kV

MECHANICAL SPECIFICATIONS				
Mechanical life expectancy	10x10 ⁶ operations			
Maximum mechanical switching rate	3,600 operations/h			
Degree of protection	IP50 fitted to socket			
Dimensions (mm)	45x90x100 ^(f)			
Weight (g)	380			

(1) Output terminals excluded.

ENVIRONMENTAL SPECIFICATIONS			
Standard operating temperature	standard	-25 to +55°C	
Version for railways, rolling stock (RMGR)		-25 to +70°C (+85°C for 10 min) -40°C as option	
Storage and shipping temperature		-25 to +85°C	
Relative humidity		Standard: 75% RH - Tropicalized: 95% RH	
Fire behaviour		VO	

See the "Operation" chapter of this document for more information and operating notes.


STANDARDS AND REFERENCE VALUE	STANDARDS AND REFERENCE VALUES				
EN 61810-1	Electromechanical elementary relays Part 1: General and safety requirements				
EN 61810-7	Electromechanical elementary relays Part 7: Test and measurement procedures				
EN 61810-3, type A ⁽¹⁾	Electromechanical elementary relays Part 3: Relays with forcibly guided (mechanically linked) contacts (2)				
EN 60695-2-10	Fire hazard testing Part 2-10: Glowing/hot-wire based test methods				
EN 61000	Electromagnetic compatibility				
EN 60529	Degrees of protection provided by enclosures (IP Code)				

Unless otherwise specified, the products are designed and manufactured according to the requirements of the above-mentioned European and International standards.

In accordance with EN 61810-1, all technical data are referred to ambient temperature of 23°C, atmospheric pressure of 96kPa and 50% humidity. Tolerance for coil resistance and nominal power is 5%.

- (1) Gap verification as per method described at §5.3.1.1 b.
- (2) Vibration resistance, frequency range, f = 10 \div 200 Hz no contact opening up to 0.828G Shocks resistance: 15 G no damages

RAILWAYS, ROLLING STOCK - STANDARDS APPLICABLE TO RMGR VERSIONS					
EN 60077-2	Railway applications - Electric equipment for rolling stock Part 2: Electrotechnical components - General rules				
EN 50155	Railway applications - Rolling stock - Electronic equipment - T3 class Testing				
EN 61373	Railway applications - Rolling stock equipment - Shock and vibration tests, Cat 1, Classe B Vibration resistance, frequency range $f = 5 \div 150$ Hz (1)				
EN 45545-2	Railway applications - Fire protection on railway vehicles Part 2: Requirements for fire behavior of materials and components HL3: Cat E10 (R26 requirement)				
ASTM E162, E662, E1354	Fire behavior – Standard test method				
BSS7239	Fire behavior - Toxicity Test				









CONFIGURATIONS - OPTIONS

TROPICALIZATION	Surface treatment of coil with protective coating for use in conditions of RH 95%. This treatment serves to give the coil added protection against corrosion that could occur as a result of moisture reacting with certain chemical agents such as those found in acid or saline atmospheres.	
GOLD PLATING Surface treatment of contacts with gold, thickness $\geq 5\mu$ (since 2023, May). This treatment ensures to the contact to conduct low levels of current, even in adverse ambient conditions.		
LED	LED indicator showing presence of power supply, wired in parallel with the coil.	
FLYBACK DIODE	Component connected in parallel with the coil designed to suppress overvoltages generated by the coil when de-energized.	
LOW TEMPERATURE	Minimum operating temperature -40°C, only for rolling stock version (option "L").	



ORDERING SCHEME							
PRODUCT CODE	APPLICATION (1)	CONFIGURATION A	CONFIGURATION B	TYPE OF POWER SUPPLY	NOMINAL VOLTAGE (V) (2)	FINISH (3)	KEYING POSITION CODE (4)
RMG	E: Energy F: Railway Fixed Equipment R: Railway Rolling stock	1: Standard 2: Gold plating + Diode // + Led 3: Diode // 4: Gold plating 5: Led 6: Gold plating + Diode // 7: Diode // + Led	2X: 6 SPDT contacts + 2 NO 6X: 6 SPDT contacts + 2 NO with magnetic arc blow-out	C: Vdc	024 - 036 - 048 072 - 096 - 110 125 - 132 - 220	T: Tropicalized coil L: Low temperature	XX

a. [RMG	E	3	6X	С	048	Т	
nple								
Exal	RMG R 7 2X C 110							
_	RMGR72X-C110 = RAILWAY series relay, equipped with flyback diode and indicator Led and 110Vdc coil.							


^{1.} **ENERGY:** all applications except for railway.

RAILWAYS, FIXED EQUIPMENT: application on fixed power systems and electrical railway traction. Construction according to RFI (FS Group, Italy) specification n° RFI DPRIM STF IFS TE 143 A, if $applicable \ for \ list \ of \ RFI \ approved \ and \ conforming \ products, \ consult \ dedicated \ catalogue \ "RAILWAY \ SERIES - \ RFI \ APPROVED"$ $\textbf{RAILWAYS, ROLLING STOCK:} \ \ \text{Application on board rolling stock.} \ \ \text{Electrical characteristics according to EN60077.}$

- 2. Other values on request.
- 3. Optional value.
- $4. \ \ \text{Optional value}. \ \text{The positive mechanical keying is applied according to the manufacturer's model}.$





WIRING DIAGRAM





DIMENSIONS






RMG.x2X - RMG.x6X



^(*) access to the manual operating lever





Contact loading: 110Vdc, L/R 40 ms

Curve A: RMG.x6X Curve B: RMG.x2X

RMG.x2X							
U	I (A)	L/R (ms)	Operations				
110Vdc	0.5	40	100,000				
110Vdc	0.6	10	300,000				
120Vdc	0.7	40	50,000				
125Vdc	1.2	0	1,000,000				
220Vdc	0.1	40	100,000				
220Vdc	0.25	10	100,000				
U	I (A)	cosφ	Operations				
110Vac	1	1	2,000,000				
110Vac	1	0.5	1,500,000				
110Vac	5	1	1,000,000				
110Vac	5	0.5	500,000				
220Vac	0.5	1	2,000,000				
220Vac	1	0.5	600,000				
220Vac	5	1	650,000				
220Vac	5	0.5	600,000				

RMG.x6X						
U	I (A)	L/R (ms)	Operations			
24Vdc	1	0	7,000,000			
24Vdc	1	40	3,000,000			
24Vdc	2	40	2,000,000			
24Vdc	5	0	3,000,000			
24Vdc	5	40	200,000			
24Vdc	9	0	800,000			
48Vdc	5	20	200,000			
110Vdc	0.4	40	1,000,000			
110Vdc	1	40	100,000			
110Vdc	10	0	100,000			
U	I (A)	cosφ	Operations			
220Vac	5	0.5	100,000			
220Vac	10	1	100,000			
230Vac	1	0.7	2,500,000			
230Vac	3	0.7	1,200,000			

Switching frequency: 1,200 operations/hour

SOCKETS AND RETAINING CLIPS			RETAINING CLIP
Type of installation	Type of outputs	Model	
Wall or DIN rail mounting	Screw	96IP20-I DIN	RMC48
	Spring clamp	PAIR320	
Flush mounting	Double faston (4.8 x 0.8 mm)	ADF4-E1	
	Spring clamp	PRIR321	

INSTALLATION, OPERATION AND MAINTENANCE



Installation

Before installing the relay on a wired socket, disconnect the power supply.

The preferential mounting position is on the wall, with the relay positioned horizontally in the "reading orienting" of marking so that the label is readable in the correct sense.

Spacing: the distance between adjacent relays depends on use' conditions.

If a relay is used in the "less favorable" conditions that occur with "simultaneously":

Power supply: the maximum allowed, permanently
 Ambient temperature: the maximum allowed, permanently
 Current on the contacts: the maximum allowed, permanently

• Number of contacts used: 100%

it is strongly recommended to space relay at least 5 mm horizontally and 20 mm vertically, to allow for proper upward heat' dissipation and increase the longevity of the component.

Actually, relays could be used in less severe conditions. In this case, the distance between adjacent relays can be reduced or abolished. A correct interpretation of the use' conditions allows the optimization of the available spaces. Contact AMRA for more information.

To increase relay' longevity, we recommend mounting relays intended for "continuous use" (permanent power supply), alternating them with relays intended for less frequent use.

For a safe use, the retaining clip is recommended. For use on rolling stock, relays have been tested to EN 61373 standard equipped with retaining clip(s).



Operation

Before use: if relay is not used, for example after long storage periods, contact resistance may increase due to a natural and slight oxidation or polluting deposits.

In order to restore the optimal conductivity and for standard contacts (NOT gold plated) it is recommended to switch several time a load of at least 110Vdc - 100mA or 24Vdc - 2A. The contacts will be "cleaned" thanks to the electric arc generated during the current interruption and the mechanical self-cleaning action.

The common contact rubs against the fixed poles (NO and NC contacts) both when opening and when closing, which ensures a self-cleaning action.

An increase in contacts' resistance, in most cases, does not represent a problem. Many factors contribute to the correct use of contact and consequently to the relay' long-term reliability:

- · Load: the current switching generates an electric arc with cleaning effects. For proper electrical cleaning and performance keeping we recommend:
 - Minimum current = 20mA (20V) o Standard contacts: o Gold plated contacts: Minimum current = 10mA (20V)
- Operating frequency: relays are components that can operate with a wide range of switching frequency. High frequency operation also allows a continuous cleaning effect by "sliding" (mechanical cleaning). In case of low frequency operation (for example few time a day), we advise:
 - o Use of contact with currents twice compared to those indicated.
 - o For currents lower than 10mA, use gold plated contacts and connect 2 contacts in parallel, in order to reduce the equivalent contact resistance
- · Pollution: the presence of pollution can cause impurities on contact surface. Electric charges attract organic molecules and impurities that are deposited on the contact surface. Electrical and mechanical cleaning, respectively, burn and remove such impurities. In pollution presence, the minimum recommended currents must be respected. In extreme cases, provide double the cleaning current.

While a contact open high loads, impurities develop inside the relay due to the formation and interruption of the electric arc. These impurities are greater the higher the load and the more frequent the switching operation. These impurities could deposit on the adiacent contacts and alter the initial conductivity characteristics. If all contacts are used with similar loads, this is not a problem. Please, contact AMRA for further informations.


The possible formation of condensation inside the relay, when it is powered and the external ambient temperature is cold, is a normal phenomenon that has no effect on the electrical safety of the relay. In case of polluted or saline atmosphere, any condensation deposits on the contacts can degrade their performance in terms of conductivity.

Maintenance

No maintenance is required.

In case of normal relay wear (reaching the end of electrical or mechanical life), the relay cannot be restored and must be replaced.

To check the component, relay removal must be carried out with slight lateral movements. An "up and down" movement can cause terminals damage.



Often the malfunctions are caused by power supply with inverted polarity, by external events or by use with loads exceeding the contact performance.

In case of suspected malfunction, energize relay and observe if mechanical operation of contacts / relay mechanism is performed. Pay attention to the power supply polarity, if relay is equipped with polarized components (example: diode, led).

- In case of expected operation, clean the contacts (see paragraph "OPERATION") and check if the circuit load ranges within the contact performance. If necessary, replace with relays with gold contacts. Note: the electrical continuity of contacts must be checked with adequate current.
- · If it does not work, we recommend to use a relay of the same model and configuration.

If an investigation by AMRA is required, pull-out the relay from the socket, don't remove the cap, avoid any other manipulation and contact us. You will be asked for the following data: environmental conditions, power supply, switching frequency, contact load, number of operations

The fault can be described through the "TECHNICAL SUPPORT" section of the website www.amra-chauvin-arnoux.it.

In any case, the relay cannot be repaired by the user.

Storage

Storage conditions must guarantee the environmental conditions (temperature, humidity and pollution) required for the product conservation, in order to avoid deterioration.

The product must be stored in an environment sheltered from atmospheric agents and not polluted, with an ambient temperature between -25 and +85°C with max 75% RH. In any case, there must be no condensation. Before use, please read carefully "OPERATION" section.

